

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



1 of 2

Facility Information

RESULT: Satisfactory

Permit Number: 13-51-08202
Name of Facility: North Glade E
Address: 5000 NW 177 Street
City, Zip: Carol City 33055

Correct By: Next Inspection
Re-Inspection Date: None

Type: Public Schools
Owner: M-DCSB Food and Nutrition
Person In Charge: Ann Lewis Phone: (305) 624-3608
PIC Email: annlewis@dadeschools.net

Inspection Information

Purpose: Routine
Inspection Date: 7/30/2020

Begin Time: 10:15 AM
End Time: 11:15 AM

Additional Information

FEMALES 97
MALES 77

CENSUS 174

This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.

Violation Markings

SCHOOL SANITATION	IN	11. Group Toilet Rooms	IN	21. Pest Control
IN 1. School Site	IN	12. Toilet Facilities		SAFETY
IN 2. Playground, Equip & Athletic Fields*	OUT	13. Handwashing Facilities	IN	22. First Aid Kit
IN 3. Athletic & Playground Equipment	IN	14. Soap Dispensers		DIAPER CHANGING STATION
BUILDING CONST/MAINT.	IN	15. Shower Facilities	NA	23. Sanitizers
IN 4. Construction	IN	16. Showers Water Temperatures	NA	24. Changing Station & Mats
OUT 5. Maintenance & Repair		WATER SUPPLY	NA	25. Hand Sink
IN 6. Lighting Standards	IN	17. Approved Source	NA	26. Garbage Can
IN 7. Heating, Ventilation, A/C Standards	IN	18. Drinking Fountains		ANIMAL HEALTH & SAFETY
IN 8. Natural Ventilation		LIQUID WASTE & WASTE WATER	NA	27. Animal Maintenance/Aggressive
IN 9. Mechanical Ventilation	IN	19. Sewage Disposal		DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	IN	20. Solid Waste	NA	28. Maintenance/Complaint
IN 10. Provided/Accessible/Separation		PEST CONTROL	NA	29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: * = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

JS LATA

Client Signature:

Emarled to client

STATE OF FLORIDA
DEPARTMENT OF HEALTH
COUNTY HEALTH DEPARTMENT
PUBLIC SCHOOL
INSPECTION REPORT



2 of 2

General Comments

The principal indicated that a Safety Form was submitted for Termite infestation in Rooms in Building 2 on 06/25/2020.

Facility is being cleaned and disinfected.

Email Address(es): annlewis@dadeschools.net;
IPalacio@dadeschools.net;
JWare@dadeschools.net;
jaybolton@dadeschools.net;

Violations Comments

Violation #5. Maintenance & Repair

Damaged baseboard at the entrance to Room 19 and in Room 7-024. Repair/replace baseboard.

Missing/loose/water stained ceiling tiles in Room 20, 22,6,5, 7-024. Replace ceiling tiles.

Burned out lights in Room 2, 5, 11, 13, 15, 17 & Restroom in 7-024. Replace lights.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

Violation #13. Handwashing Facilities

No water at faucet in Female Restroom 6-018. Provide water to faucet.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Jeffericia Scott (913251)
Inspector Contact Number: Work: (305) 623-3500 ex.
Print Client Name: North Glade E
Date: 7/30/2020

Inspector Signature:

JS

Client Signature:

Emmanuel Isidoro