

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



1 of 2

**Facility Information**

**RESULT: Satisfactory**

Permit Number: 13-51-08202  
Name of Facility: North Glade E  
Address: 5000 NW 177 Street  
City, Zip: Carol City 33055

**Correct By: Next Inspection**  
**Re-Inspection Date: None**

Type: Public Schools  
Owner: MDCPS  
Person In Charge: Lisa Bell Phone: 3056243608  
PIC Email: lisabell@dadeschools.net

**Inspection Information**

Purpose: Routine  
Inspection Date: 3/20/2025

Begin Time: 12:10 PM  
End Time: 01:12 PM

**Additional Information**

FEMALES ..... 105  
MALES ..... 118

CENSUS ..... 223

*This form serves as a "Notice of Non-Compliance" pursuant to section 120.695, Florida Statutes. Items marked below violate one or more of the requirements of Rule 6A-2.0010, of the Florida Administrative Code, Chapter 5, section 5 of the State Requirements for Educational Facilities 2014 (SREF); and sections 453 and 468 of the Florida Building Code 6th Edition (2017). Violations must be corrected within the time period indicated above. Continued operation of this facility without making these corrections is a violation. Failure to correct violations in the time frame specified may result in enforcement action being initiated by the Department of Health.*

**Violation Markings**

SCHOOL SANITATION	<b>IN</b> 11. Group Toilet Rooms	<b>IN</b> 21. Pest Control
<b>IN</b> 1. School Site	<b>IN</b> 12. Toilet Facilities	SAFETY
<b>IN</b> 2. Playground, Equip & Athletic Fields*	<b>OUT</b> 13. Handwashing Facilities	<b>IN</b> 22. First Aid Kit
<b>IN</b> 3. Athletic & Playground Equipment	<b>IN</b> 14. Soap Dispensers	DIAPER CHANGING STATION
BUILDING CONST/MAINT.	<b>IN</b> 15. Shower Facilities	<b>NA</b> 23. Sanitizers
<b>IN</b> 4. Construction	<b>IN</b> 16. Showers Water Temperatures	<b>IN</b> 24. Changing Station & Mats
<b>OUT</b> 5. Maintenance & Repair	WATER SUPPLY	<b>IN</b> 25. Hand Sink
<b>IN</b> 6. Lighting Standards	<b>IN</b> 17. Approved Source	<b>IN</b> 26. Garbage Can
<b>IN</b> 7. Heating, Ventilation, A/C Standards	<b>IN</b> 18. Drinking Fountains	ANIMAL HEALTH & SAFETY
<b>IN</b> 8. Natural Ventilation	LIQUID WASTE & WASTE WATER	<b>NA</b> 27. Animal Maintenance/Aggressive
<b>IN</b> 9. Mechanical Ventilation	<b>IN</b> 19. Sewage Disposal	DORM/RESIDENTIAL FACILITIES
SANITARY FACILITIES	<b>IN</b> 20. Solid Waste	<b>NA</b> 28. Maintenance/Complaint
<b>IN</b> 10. Provided/Accessible/Separation	PEST CONTROL	<b>IN</b> 29. Other

Marking Key: **IN** = the act or item was observed to meet standards; **OUT** = the act or item was observed not to meet standards; **NO** = the act or item was not observed to be occurring at the time of inspection; **NA** = the act or item is not performed by the facility or not part of the operation

Violation Key: \* = 2. Playground, Equipment & Athletic Fields

Inspector Signature:

Client Signature:

STATE OF FLORIDA  
DEPARTMENT OF HEALTH  
COUNTY HEALTH DEPARTMENT  
PUBLIC SCHOOL  
INSPECTION REPORT



2 of 2

### General Comments

Satisfactory.

Email Address(es): pr3861@dadeschools.net;  
lisabell@dadeschools.net;  
ipalacio@dadeschools.net;  
wcabrera@dadeschools.net;  
mwertz@dadeschools.net

### Violations Comments

#### Violation #5. Maintenance & Repair

At the time of this inspection, lightbulbs out of service were observed in the following classrooms: 17,13,1,2 and 4. Replace lightbulbs out of service.

At the time of this inspection, ceiling tiles with water marks were observed in the following classrooms: 17 and 1. Replace ceiling tiles.

At the time of this inspection, missing ceiling tiles were observed in classroom # 5. Replace ceiling tiles.

CODE REFERENCE: 5. Maintenance and Repair. 5(1)(e)8.h SREF. Light fixtures and window surfaces, both inside and outside, shall be kept clean, serviceable, and in good repair at all times. 5(1)(e)8.i. Custodial areas shall be kept clean, safe, and orderly at all times. Custodial equipment shall be in good repair at all times. 5(1)(e)8.j SREF. Building components & finishes shall be kept clean & in good repair.

#### Violation #13. Handwashing Facilities

At the time of this inspection, the hand dryer machine was observed out service in restroom 6-019. Repair or replace hand dryer machine.

CODE REFERENCE: 13. Handwashing Facilities. 5(13)(h)1 SREF. Hot and cold water shall be provided in toilet rooms at the lavatory. Hot water temperature shall not exceed 110°F. 468.3.5.7.1 FBC. Handwashing facilities shall be located within or adjoining each toilet room.

Inspection Conducted By: Pedro Hernandez Bastidas (60752)  
Inspector Contact Number: Work: (305) 623-3500 ex.  
Print Client Name: Lisa Bell  
Date: 3/20/2025

Inspector Signature:

Handwritten signature of Pedro Hernandez Bastidas.

Client Signature:

Handwritten signature of Lisa Bell.